

MATERIAL TESTING LABORATORY

MILITARY ENGINEER SERVICES (MES)

TEST RESULTS FOR TENSILE STRENGTH OF PLAIN/DEFORMED/RIBBED COLD TWISTED M.S. BARS

Job No : 255/2018-2019 (Steel). Copy No. : 01

Name of Client : GE(Army) Chattogram. : Length 600 mm Dia 10mm

Ref Itr No : EinC/ 371 of 2017-2018/13/E-6 Dt. 24 March 2019. Sample Grade : 60

Project Name : EinC/ 371 of 2017-2018. Frog Mark : BSRM 420.

Date of Collection : Thursday, 28 March, 2019

| Sample No | Nominal Dia | Actual Dia | Area Under Test | Actual Unit Weight | Average Actual Unit Weight | Yield or Proof Load | Yield or Proof Strength | Average Yield or Proof Strength | Ultimate Load | Ultimate Strength | Average Ultimate Strength | % (g | gation gauge gth) | Average Elongation % (gauge length) | |
|--------------|----------------|----------------|--------------------|-----------------------|----------------------------------|------------------------|-------------------------------|--|-------------------|----------------------|---------------------------------|-------|-------------------------|--|------|
| | inch mm | inch mm | sq.inch sq.mm | lb/ft kg/m | lb/ft kg/m | lb kn | psi Mpa | psi Mpa | lb kn | psi Mpa | psi Mpa | 8inch | 5d** | 8inch | 5d** |
| 1 | 0.394 10 | 0.393 9.977 | 0.1217 78.5398 | 0.412 0.614 | | 9183.49 40.85 | 75437 520 | | 12854.64 57.18 | 105594 728 | | 19 | | | |
| 2 | 0.394 10 | 0.393 9.977 | 0.1217 78.5398 | 0.412 0.614 | 0.412 0.614 | 9183.49 40.85 | 75437 520 | 75234 519 | 12854.64 57.18 | 105594 728 | 105538 728 | 21.5 | | 20 | |
| 3 | 0.394 10 | 0.393 9.977 | 0.1217 78.5398 | 0.412 0.614 | | 9109.3 40.52 | 74828 516 | | 12834.4 57.09 | 105428 727 | | 20 | | | |

Cautions:

- 1. Samples as supplied to the laboratory have been tested. The laboratory authority does not bear any responsibility as to the representative charecter of the samples to be tested.
- 2. It is recommended that the samples are sent in a secure and sealed cover/packet/container under signature of the competent authority.
- 3. In order to avoid fraudulent fabrication of the test results, it is recommended that all test reports should be collected by duly authorized person and not by the contractor/supplier.

Observation on Specimen(if any):

1.Diameter & Unit weight of 10 mm bar is less than the standard value but within tolerance limit according to MES Schedule of Rates-2016.

| Minimu | m Standard | Requiremen | its (BDS/ISO | Minimum Standard Requirments(ASTM A615/A616M-96a) | | | | | | | | | | |
|----------------|-----------------|-----------------|--------------|---|-----------------|-----------------|--------------|-----------------|-----------------|---|-------------|-------------|----------------|--|
| 6935-2:1991(E) | | | | ASTM A 615 M | | | ASTM A 615 M | | | ASTM A 615/A 615 M | | | | |
| Grade | Y/strength | Ult.Str | Elongation | Grade | Y/strength | Ult.Str | Grade | Y/strength | Ult.Str | Minimum Elongation in 8"(203.2 mm) GL (%) | | | | |
| | N/mm2 or Mpa | N/mm2 or Mpa | % | | psi (kg/cm2) | psi (kg/cm2) | | Mpa (kg/cm2) | Mpa (kg/cm2) | 10 mm | 13,16,19 mm | 22,25 mm | 29,32,36 mm | |
| 300 | 300 | 330 | 16 | 40 | 40000(2810) | 70000(4910) | 300 | 300(3050) | 500(5090) | 11 | 12 | | | |
| 400/400w | 400 | 440 | 14 | 60 | 60000(4210) | 90000(6310) | 420 | 420(4275) | 620(6295) | 9 | 9 | 8 | 7 | |
| 500/500w | 500 | 550 | 14 | 75 | 75000(5255) | 100000(7015) | 520 | 520(5275) | 690(7010) | | 7 | 7 | 6 | |

This is a computer genarated copy

No signature is required

Note : [1 Mpa = 145 Psi, 1 kg/cm2 = 14.223 psi]

Laboratory Technichian

Test Performed By

Vetted By