

# MATERIAL TESTING LABORATORY

## **MILITARY ENGINEER SERVICES (MES)**

#### TEST RESULTS FOR TENSILE STRENGTH OF PLAIN/DEFORMED/RIBBED COLD TWISTED M.S. BARS

Job No : 265/2018-2019 (Steel). Copy No. : 04

Name of Client : GE(Army) Comilla. Sample Specimen : Length 600 mm Dia 20mm

Ref Itr No : CEA/ 317 of 2018-2019/03/E-6 Dt. 03 April 2019. Sample Grade : 60

Project Name : CEA/ 317 of 2018-2019. Frog Mark : BSRM 420
Date of Collection : Wednesday, 03 April, 2019

Sample No	Nominal Dia	Actual Dia	Area Under Test	Actual Unit Weight	Average Actual Unit Weight	Yield or Proof Load	Yield or Proof Strength	Average Yield or Proof Strength	Ultimate Load	Ultimate Strength	Average Ultimate Strength	Elongation % (gauge length)		Average Elongation % (gauge length)	
	inch mm	inch mm	sq.inch sq.mm	lb/ft kg/m	lb/ft kg/m	lb kn	psi Mpa	psi Mpa	lb kn	psi Mpa	psi Mpa	8inch	5d**	8inch	5d**
1	0.787 20	0.782 19.856	0.4869 314.1593	1.634 2.431		33690.03 149.86	69186 477		49680.76 220.99	102025 703		26			
2	0.787 20	0.782 19.856	0.4869 314.1593	1.634 2.431	1.634 2.431	33132.5 147.38	68041 469	68680 473	49745.96 221.28	102159 704	102114 704	28		28	
3	0.787 20	0.782 19.856	0.4869 314.1593	1.634 2.431		33507.93 149.05	68812 474		49745.96 221.28	102159 704		28.5			

### **Cautions:**

- 1. Samples as supplied to the laboratory have been tested. The laboratory authority does not bear any responsibility as to the representative charecter of the samples to be tested.
- 2. It is recommended that the samples are sent in a secure and sealed cover/packet/container under signature of the competent authority.
- 3. In order to avoid fraudulent fabrication of the test results, it is recommended that all test reports should be collected by duly authorized person and not by the contractor/supplier.

### **Observation on Specimen(if any):**

1.Diameter & Unit weight of 20 mm bar is less than the standard value but within tolerance limit according to MES Schedule of Rates-2016.

Minimu	m Standard	Requiremen	nts (BDS/ISO	Minimum Standard Requirments(ASTM A615/A616M-96a)										
6935-2:1991(E)				ASTM A 615 M			ASTM A 615 M			ASTM A 615/A 615 M				
Grade					Ult.Str	Grade	Y/strength	Ult.Str	Minimum Elongation in 8"(203.2 mm) GL (%)					
	N/mm2 or	Contraction of the Contraction o	7000		psi	psi		Mpa	Mpa	10	13,16,19 mm	22,25	29,32,36	
	Mpa	Mpa	%		(kg/cm2)	(kg/cm2)		(kg/cm2)	(kg/cm2)	mm		mm	mm	
300	300	330	16	40	40000(2810)	70000(4910)	300	300(3050)	500(5090)	11	12			
400/400w	400	440	14	60	60000(4210)	90000(6310)	420	420(4275)	620(6295)	9	9	8	7	
500/500w	500	550	14	75	75000(5255)	100000(7015)	520	520(5275)	690(7010)	1946	7	7	6	

This is a computer genarated copy

No signature is required

Note : [1 Mpa = 145 Psi, 1 kg/cm2 = 14.223 psi]

Laboratory Technichian

Test Performed By

Vetted By