

# MATERIAL TESTING LABORATORY

### **MILITARY ENGINEER SERVICES (MES)**

#### TEST RESULTS FOR TENSILE STRENGTH OF PLAIN/DEFORMED/RIBBED COLD TWISTED M.S. BARS

Job No : 145/19-20(Steel). Copy No. : 02

Name of Client : GE (Air) Chattogram. Sample Specimen : Length 600 mm Dia 12mm

Ref Itr No : 6005/43/20/E-6 Dt. 05 September'2019. Sample Grade : 60

Project Name : EinC/225 of 2017-2018. Frog Mark : AKS 500W

Date of Collection : Wednesday, 11 September, 2019

Sample No	Nominal Dia	Actual Dia	Area Under Test	Actual Unit Weight	Average Actual Unit Weight	Yield or Proof Load	Yield or Proof Strength	Average Yield or Proof Strength	Ultimate Load	Ultimate Strength	Average Ultimate Strength	% (g	gation gauge gth)	Average Elongation % (gauge length)	
	inch mm	inch mm	sq.inch sq.mm	lb/ft kg/m	lb/ft kg/m	lb kn	psi Mpa	psi Mpa	lb kn	psi Mpa	psi Mpa	8inch	5d**	8inch	5d**
1	0.472 12	0.472 11.984	0.1753 113.0973	0.595 0.886	0.595 0.886	14857.69 66.09	84755 584	85649 590	17658.83 78.55	100734 694	101179 698	14.5		15	
2	0.472 12	0.472 11.984	0.1753 113.0973	0.595 0.886		15136.46 67.33	86346 595		17786.97 79.12	101465 700		14			
3	0.472 12	0.472 11.984	0.1753 113.0973	0.595 0.886		15048.78 66.94	85845 592		17764.49 79.02	101337 699		15			

## **Cautions:**

- 1. Samples as supplied to the laboratory have been tested. The laboratory authority does not bear any responsibility as to the representative charecter of the samples to be tested.
- 2. It is recommended that the samples are sent in a secure and sealed cover/packet/container under signature of the competent authority.
- 3. In order to avoid fraudulent fabrication of the test results, it is recommended that all test reports should be collected by duly authorized person and not by the contractor/supplier.

### **Observation on Specimen(if any):**

1.Diameter & Unit weight of 12 mm bar is less than the standard value but within tolerance limit according to MES Schedule of Rates-2016.

Minimum Standard Requirements (BDS/ISO 6935-2:1991(E)				Minimum Standard Requirments(ASTM A615/A616M-96a)									
				ASTM A 615 M			ASTM A 615 M			ASTM A 615/A 615 M			
Grade	Y/strength					Grade	Y/strength Ult.Str Minimum Elongation in 8"(203.2 mm) GL (%				GL (%)		
	N/mm2 or	Contraction of the Contraction o	7000		psi	psi		Mpa	Mpa	10	13,16,19 mm	22,25	29,32,36
	Mpa	Mpa	%		(kg/cm2)	(kg/cm2)		(kg/cm2)	(kg/cm2)	mm		mm	mm
300	300	330	16	40	40000(2810)	70000(4910)	300	300(3050)	500(5090)	11	12		
400/400w	400	440	14	60	60000(4210)	90000(6310)	420	420(4275)	620(6295)	9	9	8	7
500/500w	500	550	14	75	75000(5255)	100000(7015)	520	520(5275)	690(7010)	1946	7	7	6

This is a computer genarated copy

No signature is required

Note : [1 Mpa = 145 Psi, 1 kg/cm2 = 14.223 psi]

Laboratory Technichian

Test Performed By

Vetted By