

# MATERIAL TESTING LABORATORY

## **MILITARY ENGINEER SERVICES (MES)**

### TEST RESULTS FOR COMPRESSIVE STRENGTH OF CONCRETE CYLINDER/CUBE

Job No : 856/19-20 (Con).

Name of Client : AGE (Air) Shamshernagar. Copy No. : 02

Ref Itr No : CE/Air-286 of 2018-2019/19/E-6 Dt.03Feb'2020. Sample Specimen : HT 200mm (8"), Dia 100mm (4")

Project Name : CE/Air-286 of 2018-2019. Type of Aggregate : Brick

Status of Sample : 4th floor roof slab. Brand & Type of Cement : Seven rings opc

Date of Collection : Tuesday, 04 February, 2020 Proportion of Mixture : 1:2:4

Test Standard : ASTM/BS Desired Design Strength : 2500 psi

Ser No	Date of Casting and (Age in days)	Date of Test	Specimen Area Sq inch	Maximum Load (Lbs.)	Crushing Strength (psi)	Average Crushing Strength (psi)	Type of Failure
1			12.17	35190	2892		
2	29-Jan-20 (28 days)	26-Feb-20	12.17	7739	636	2010	Aggregate/ Morter or Both Failure
3			12.17	30458	2503		

#### **Cautions:**

- 1. Samples as supplied to the laboratory have been tested. The laboratory authority does not bear any responsibility as to the representative charecter of the samples to be tested.
- 2. It is recommended that the samples are sent in a secure and sealed cover/packet/container under signature of the competent authority.
- 3. In order to avoid fraudulent fabrication of the test results, it is recommended that all test reports should be collected by duly authorized person and not by the contractor/supplier.

## **Observation on Specimen(if any):**

1.As the strength is below the desired design strength, so nec. measures to be taken as per particular specifications of contract.

Laboratory Technichian Test Performed By Vetted By

This is a computer genarated copy

No signature is required

### **Permissible Value:**

1.

Note: [1 Mpa = 145 Psi, 1 kg/cm2 = 14.223 psi]